

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0075:156 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Fire-Lite Alarm Inc., One Fire-Lite Place, Northford, CT 06472-1653
Contact: *Brian Reynolds (203) 484-1200 FAX (203) 484-7309

DESIGN: Model CP300 ionization type smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization type smoke detector for use with Fire-Lite's separately listed Model MS-9200 control panel (CSFM Listing No. 7165-0075:158).

XLF: 7271-1209:150

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**